



# CERTIFICATE NCS/FI 28796

Our Ref. 277542-1

<b>Product</b>	Range of enclosures	
<b>Type</b>	MNX...	
<b>Trade mark</b>	FIBOX	
<b>Certificate Holder/ Manufacturer</b>	Fibox Oy Ab HTC Center Keilaranta 19 FI-02150 ESPOO, FINLAND	
<b>Technical information</b>	Degree of protection (EN 60529)	IP66 / IP67
	Mechanical strength (EN 62262)	IK08 +35 / -25°C
	Static loads	mounting plate 1 kg / dm <sup>2</sup> swing panel 1 kg
<b>Other information</b>	Material: Polycarbonate (PC) Empty enclosure The series includes the following types, see the Appendix to this Certificate	
<b>The product is certified according to the following standard(s)</b>	EN 62208:2011	
<b>Validity</b>	This certificate is valid until 23 September 2019 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.	
<b>Directive information</b>	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.	
<b>Date of issue</b>	23 September 2014	
<b>Signature</b>	<b>SGS Fimko Ltd</b>  Sixten Lökfors Project Manager	



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 28796

**Manufacturing site(s)** FiboxPAM Oy  
Rajasilta 6  
FI-33880 LEMPÄÄLÄ, FINLAND

**Additional information** This certificate replaces certificate NCS/FI 24457 A2 dated 14 August 2013, due to updated standard.

**The series includes the following types**

Type	size (mm)
MNX PC...	100 x 100 x 35...75
MNX PC...	130 x 80 x 35... 125
MNX PC...	130 x 130 x 35... 125
MNX PC...	180 x 130 x 35... 175
MNX PC...	180 x 180 x 60... 150
MNX PC...	255 x 180 x 63... 175
MNX PC...	360 x 255 x 152
MNX F	180 x 130 x 35...60
MNX F	180 x 180 x 60

**Is based on test / Our ref.** 252092-1, 277542-1

Supplement to Certificate: NCS/FI 28796

Internal ref.  
277542-1

23 September 2014

## NORDIC CERTIFICATION SERVICE

We hereby confirm that the product(s) appearing from the certificate with above certificate reference also comply(ies) with requirements for secondary certification in the following countries: Denmark, Norway, Sweden

### NOTIFICATION

<b>Certificate holder for Denmark, Norway, Sweden</b>	Fibox Oy Ab HTC Center Keilaranta 19 FI-02150 ESPOO, FINLAND
	Please send the invoice and the certificate directly to Certificate holder, Attn: Mr Tobias Andersson, mailto: <a href="mailto:tobias.andersson@fibox.fi">tobias.andersson@fibox.fi</a>
<b>Safety standard(s) applied</b>	EN 62208:2011
<b>Deviations</b>	Not applicable
<b>EMC requirements</b>	-
<b>The assignment is based on</b>	Testing in own premises from SGS Fimko Ltd.
<b>Limitations or reservations regarding the testing / examination performed</b>	None
<b>Certification marks</b>	Affixing of the certification mark(s) of the Nordic body(ies) on the product must not take place before notice about national certification is received from the individual body.
<b>Production surveillance</b>	Will be carried out by SGS Fimko according to agreed procedures.
<b>Other information</b>	When certificate is applied for in Norway (NEMKO), Denmark (DEMKO) and Sweden (SEMKO) a copy of this certificate and the enclosed material shall be attached to the application.
<b>Test samples must be submitted to the secondary body(ies)</b>	No
<b>Date of issue</b>	23 September 2014

This Notification may be challenged if it is more than 3 years old.

**SGS Fimko Ltd**

Signature



Sixten Lökfors  
Project Manager